


Certificate of Fire Protection Works



No. 822.2020

Argus Fire Protection Company Ltd
Hendglade House
46 New Bridge Road
Stourbridge
DY8 1PA

**Priory Fields,
Kettleby, Brigg
Lincolnshire
Tel: 01652 413110**

Properties: Westview Court Greenway Wythenshawe Manchester M22 4LT		Tel: 07785426299
		Email: k.winstanley@argusfire.co.uk
Areas of application:	Sprinkler system pipes.	
Products applied:	Firepro acoustic intumescent sealant.	
Specifics:	Fire stopping products have been applied to orange pipe breaches in boxing in on all floors.	
Installers Details		
Name: Steve Asquith	Address: Priory Fields Kettleby Brigg Lincolnshire DN20 9HN	Tel: 01652 413110
		Email: phil@flamehold.co.uk
Company Name: Flame Hold Ltd		Qualification: GFireE , FPA Fire Risk Assessor & FIRAS Accreditation – Certificate No. FD5102; FIRAS ID – S69545
I/We hereby certify that the Passive Fire Protection products/systems, supplied for the above project have been supplied & fitted by Flame Hold Ltd. To the best of my knowledge and belief – based on the information supplied – to be the appropriate products/systems for the project to provide Passive Fire Protection to achieve 30 minute fire ratings.		
Signature of Installer: 		Date: 07.12.2020

All Fire Prevention Measures should be checked annually and preventative maintenance carried out. Failure to do so may impair the performance.