



FIRE PRECAUTIONS LEGEND

- Break glass type fire alarm call point
- Heat sensitive detectors
- Smoke sensitive detectors
- Emergency light point.
- Firemans Switch
- Emergency Drop Key Access
- Fire alarm indicator / repeat panel
- Door/Access fitted with Gerda D1 Key lock
- Door/Access fitted with FB1 Key lock
- Door/Access fitted with FB2 Key lock
- Door/Access fitted with FB4 Key lock
- Door/Access fitted with FB11 Padlock
- Door/Access fitted with FB14 Padlock
- Dry Riser Outlet
- Digital electronic lock door entry/exit system
- Premises Information Box
- Permanently Open Vent
- Automatic Opening Vent
- Openable Vent
- Fire alarm sounder ('X' indicates integral flashing - Xenon light)
- CCTV Security Camera
- Fire Brigade Key Access
- EXTINGUISH**
- 1.1m x 1.1m fire blanket - base of container to be 1500mm above floor level
- 6 litres AFFF aqueous foam extinguisher to BS:6575
- 9 litre wet chemical type extinguisher
- 4.5 litre dry powder type extinguisher
- 2 kg carbon dioxide type extinguisher
- 4.5 kg carbon dioxide type extinguisher
- 9 kg water type extinguisher
- 6 litre water type extinguisher
- FIRE EXIT SIGNAGE**
- 'E' Signs to be externally illuminated by adjacent emergency light point
- 'FE' denotes as previous but illuminated as part of sign
- 'RM' denotes non illuminated sign
- FIRE DOOR SIGNS AND FIRE ACTION NOTICES**
- Fire Action Notice
- Emergency Floor Plan
- "FIRE DOOR KEEP SHUT" sign
- "FIRE DOOR KEEP LOCKED" sign
- "AUTOMATIC FIRE DOOR KEEP CLEAR" or "FIRE EXIT KEEP CLEAR" sign
- "CAUTION, IN THE EVENT OF FIRE DO NOT USE THIS LIFT"
- DISTRIBUTION BOARD

BROWNLEY COURT FOURTH FLOOR

REV | DATE | AMENDMENTS



WEB: WWW.FIRNTEC.COM
EMAIL: CONTACTUS@FIRNTEC.COM
ADDRESS: 1ST FLOOR, ENDEAVOUR HOUSE,
PARKWAY CT, PLYMOUTH PL6 8LR
TEL: 01752 877 147

PROJECT: BROWNLEY COURT
ADDRESS: BROWNLEY COURT
WYTHENSHAW
MANCHESTER
M22 8LD
DWG NO.: BR-C-220020L05
DWG TITLE: LEVEL 4
DWG DATE: NOVEMBER 2022
DWG SIZE: SCALE 1:50 @ A1
DRAWN: NR | CHECKED: BR | ISSUED