


Certificate of Fire Protection Works



No. 158B.2018

Wythenshawe Community Housing Group
Greenwood Road
Wythenshawe
M22 9HD

Priory Fields, Kettleby, Brigg
Lincolnshire DN20 9HN
Tel: 01652 413110

Property: Edwards Court Rowlands Way Wythenshawe M22 5SF		Tel: 0161 946 6362
		Email: Adrian.waywell@wchg.org.uk
Areas of application:	Red Cable breaches throughout the building.	
Products applied:	Intumescent sealant; Intumescent impregnated fireproof sponge & H E Graphite Sealant.	
Specifics:	See Overleaf	
Installers Details		
Name: Philip Asquith	Address: Priory Fields Kettleby Brigg Lincolnshire DN20 9HN	Tel: 01652 413110
		Email: phil@flamehold.co.uk
Company Name: Flame Hold Ltd		Qualification: Registered Surveyor & FPA Fire Risk Assessor
I/We hereby certify that the Passive Fire Protection products/systems, supplied for the above project have been supplied & fitted by Flame Hold Ltd. To the best of my knowledge and belief – based on the information supplied – to be the appropriate products/systems for the project to provide Passive Fire Protection to achieve 30 minute fire ratings.		
Signature of Installer: 		Date: 28 th November 2018

All Fire Prevention Measures should be checked annually and preventative maintenance carried out. Failure to do so may impair the performance.